



Alabama State Port Authority
Addendum 1 - Date: 6/30/2021
15KV High Voltage Cable
Bid Opening Date: 7/13/2021 at 10:00am

Subject: Cable Diameter

The Alabama State Port Authority hereby changes the maximum cable diameter to 55 mm.

Description
Protolon (N) TSKCGEWOEU (SMK) LWL 3X35+1X25+1X10ST+1X6 (LWL) 8,7/15KV Manufacturer: Protolon (or equivalent) Cable Diameter must not exceed 46 mm 55 mm. Length: 1260 ft. (384m)

Regards,

Dillon B. Sims
Associate Buyer
Alabama State Port Authority
251-441-7676
dsims@asdd.com