



**Alabama State Port Authority  
Third Addendum**

**Project Name:** ICTF Drainage Cured in Place Liner  
**Location:** Mobile, AL  
**Project # :** 10765      **TASK # :** 2      **April 2021**

**Third Addendum**

**ICTF Drainage  
Cured in Place Liner**

**June 1, 2021**



## **Alabama State Port Authority Third Addendum**

**Project Name:** ICTF Drainage Cured in Place Liner  
**Location:** Mobile, AL  
**Project #** 10765      **TASK #** 2      **April 2021**

1. The bid submittal deadline is extended to June 16, 2021 at 2:00 p.m. The bid opening will take place June 16, 2021 beginning at 2:00 p.m. in the Killian Room at the same address indicated in the Bid Advertisement.
2. The contractor will have the opportunity to access the pipes inside the ICTF fence line near the pipes midpoint and will be allowed to remove the top half of each of the seven pipes over a length of not more than 20 feet. The contractor shall coordinate all access and activity to said midpoint with the owner and shall not proceed without written approval from the owner of the following: excavation location, excavation depth, shoring plan, work sequence, staging area, and plan to restore pipes and work area to pre-construction conditions. The contractor shall not damage or obstruct any of the hard surfaces within the ICTF. The contractor will be required to erect temporary fence around the staging area and excavation which shall not exceed 1.5 acres.