

**ALABAMA STATE PORT AUTHORITY  
SPECIFICATIONS AND CONTRACT DOCUMENTS  
FOR  
MCDUFFIE TERMINAL BARGE UNLOADER #1 AND LOADER #1 BULKHEAD  
REPLACEMENTS  
PROJECT #10842 TASK #9 & 10**

**ADDENDUM NO. 2  
MARCH 24, 2021**

Following are responses to contractor's questions.

Can the alignment of the New Combination wall be adjusted as to not interfere with the tip of the existing wall?

**Answer: No. The alignment of the new combination wall is to be as shown on the design drawings.**

On Drawing D1 section A states that we are to remove the existing tie rods. Will the existing dead-man be abandoned and left in place?

**Answer: The existing dead-man can be abandoned in place.**

Do you guys plan on awarding individual contracts for Task 09 & Task 10? Or award both tasks to the same contractor?

**Answer: No. Both tasks will be awarded to the same contractor.**