



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name **Pier B North Warehouse – Potable Waterline Replacement**
OPN #: **10381**
Task #: **1**

ADDENDUM #3

To: Prospective Bidders

Date: 3/21/2017

Plans and specifications are hereby amended as follows:

Item	Description
1	All piping (including fittings, mechanical joints, etc.) is to be galvanized. Galvanization of piping shall be in accordance with the requirements for galvanized pipe in ASTM A53.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

Project Manager:

James J. "Josh" Bell, P.E.
 Project Manager

Date