



**Alabama State Port Authority**  
**Addendum to R&P or Specification Booklet**

**Project Name** Pier C North Rehabilitation, Phase I – Storage Yard

**AFE #** 9358      **CN #** 2032      **Addendum #** 4

**To:** Prospective Bidders

**Date:** 1/11/12

Plans and specifications are hereby amended as follows:

Item	Description
1	See the response to requests for information along with the revised Schedule of Prices, attached, which are all hereby incorporated into the Contract Documents by this Addendum.

Questions are welcome until 5 pm, Thursday, January 12, 2012. No additional questions will be addressed after this time.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

Project Manager:

Aimee W. Williams      1/11/12  
 Aimee W. Williams, P.E.      Date  
 Project Manager

# ASPA Pier C North Rehabilitation

## Phase I – Storage Yard

### ADDENDUM # 4

41. Question: The line item sheet has approx quantites, do we bid as per the number in the quantities or per our take-off? The footages for conduit and wire are off. If we bid per the listed quantities will anything over be added to our contract.

**Answer: *The Bid Item quantities for Bid Items 37, 38, 39, 40, 41, 46, and 48 are revised by this Addendum. The Contractor should bid as per Contract Specifications. Refer to General Conditions 20-04 INTERPRETATION OF ESTIMATED PROPOSAL QUANTITIES and 50-02 ALTERATION OF WORK AND QUANTITIES.***

42. Question: Reference Sheets C3.0 & C3.1. These sheets show the legend symbol for the demolition of concrete paving. This is your Bid Item No. 5 with a quantity of 8,194 square yards. There is a legend symbol for demolition of the concrete transit slab. The additional square yards of the transit slab exceeds the square yards in Bid Item No. 5. What Bid Item will the removal of the transit slab go in? Please clarify.

**Answer: *The transit shed slab removal is included in bid item #16.***

43. Question: In reading the specifications it states that we need to backfill certain areas of demo work such as conveyor pit and transition slab foundations. Will the material brought in to backfill these areas be paid as borrow or shall it be included in the lump sum price for the demo work.

**Answer: *Material to backfill the conveyor pit will be paid as part of the lump sum for Bid Item #3. Material to backfill the transit shed slab foundation area is included in Bid Item #11.***

On the Schedule of Prices, Bid Item No. 37 approximate quantity is changed from 100 Linear Foot to **150** Linear Foot.

On the Schedule of Prices, Bid Item No. 38 approximate quantity is changed from 4,580 Linear Foot to **5,100** Linear Foot.

On the Schedule of Prices, Bid Item No. 39 approximate quantity is changed from 4,955 Linear Foot to **5,200** Linear Foot.

On the Schedule of Prices, Bid Item No. 40 approximate quantity is changed from 1,530 Linear Foot to **2,000** Linear Foot.

On the Schedule of Prices, Bid Item No. 41 approximate quantity is changed from 2,730 Linear Foot to **3,400** Linear Foot.

# ASPA Pier C North Rehabilitation

## Phase I – Storage Yard

### ADDENDUM # 4

On the Schedule of Prices, Bid Item No. 46 approximate quantity is changed from 4,265 Linear Foot to **4,650** Linear Foot.

On the Schedule of Prices, Bid Item No. 48 approximate quantity is changed from 1,165 Linear Foot to **1,180** Linear Foot.

Because of the Bid Item Changes, the Schedule of Prices is replaced in its entirety.

# ASPA Pier C North Rehabilitation

## Phase I – Storage Yard

### ADDENDUM # 4

#### SCHEDULE OF PRICES

Item	Description	Approx. Quantities	Unit	Unit Price	Dollar Amount
1	Mobilization/Demobilization, Bonding, Permits, Access Credentials	1	Lump Sum	\$	\$
2	Demolition/Removal of Transit Shed Retaining Wall	1	Lump Sum	\$	\$
3	Demolition/Removal of Rail Car Conveyor Pit	1	Lump Sum	\$	\$
4	Demolition/Removal of Rail	1	Lump Sum	\$	\$
5	Demolition/Removal of Concrete Paving	8,194	Square Yard	\$	\$
6	Grate Inlets	2	Each	\$	\$
7	Remove Existing Manhole Ring, Cover and Cone Section and Install Grate Inlet Top	6	Each	\$	\$
8	Reinforced Concrete Pipe	224	Linear Foot	\$	\$
9	Temporary Erosion Control	1	Lump Sum	\$	\$
10	Unclassified Excavation	750	Cubic Yard	\$	\$
11	Structural Fill	7,500	Cubic Yard	\$	\$
12	Asphalt Overlay	1,250	Square Yard	\$	\$
13	Full Depth Asphalt Paving	30	Square Yard	\$	\$
14	Interlocking Pavers	28,000	Square Yard	\$	\$
15	Concrete Curb	2,185	Linear Foot	\$	\$
16	Demolition/Removal of Existing Transit Shed Foundation	1	Lump Sum	\$	\$
17	Load Test Pressure Grouted Auger Piling (Augercast Piling)	1	Lump Sum	\$	\$
18	Pressure Grouted Auger Piling (Augercast Piling)	16,510	Linear Foot	\$	\$

# ASPA Pier C North Rehabilitation

## Phase I – Storage Yard

### ADDENDUM # 4

Item	Description	Approx. Quantities	Unit	Unit Price	Dollar Amount
19	Transition Slab Concrete	1,655	Cubic Yard	\$	\$
20	Transition Concrete From Pavers Across to Transition Slab	488	Cubic Yard	\$	\$
21	Excavation, Concrete Paving Seat and Cap, and Backfill	1	Lump Sum	\$	\$
22	Removal of Existing Storm Drainage Structures	6	Each	\$	\$
23	Removal of Existing Storm Drainage Pipe (Various Sizes)	975	Linear Foot	\$	\$
24	Storm Drainage Pipe Concrete Plug	1	Each	\$	\$
25	Removal/Disposal of Contaminated Soil	125	Ton	\$	\$
26	Removal and Disposal of 8" Bunker Fuel Oil Line	1,150	Linear Foot	\$	\$
27	Removal/Disposal of 8" Fire Main	1,150	Linear Foot	\$	\$
28	High Mast Light Pole - 100'-0", Galvanized Steel with Motorized Lowering Lighting Ring with 12 - 1000W HPS High Mast Lights with Elevated Base.....as shown in the Contract Documents	5	Each	\$	\$
29	High Mast Light Pole - 100'-0", Galvanized Steel with Motorized Lowering Lighting Ring with 6 - 1000W HPS High Mast Lights with Elevated Base.....as shown in the Contract Documents	1	Each	\$	\$
30	"On-Off" Pushbutton NEMA 4X Switch Box with Heavy Duty Oil tight Pushbuttons with "ON" and "OFF" Name plates	1	Each	\$	\$
31	100A, 480V, 3-Pole Lighting Contactor to be mounted in existing enclosures	1	Each	\$	\$
32	Lighting Control Panel "7C" - 100A, 480V, 3Ø, NEMA 1, Surface Mounted	1	Each	\$	\$

# ASPA Pier C North Rehabilitation

## Phase I – Storage Yard

### ADDENDUM # 4

Item	Description	Approx. Quantities	Unit	Unit Price	Dollar Amount
	with Circuit Breakers as indicated in the Contract Documents				
33	Lighting Control Panel "7C" - 60A, 480V, 3Ø, NEMA 1, Surface Mounted with Circuit Breakers as indicated in the Contract Documents	1	Each	\$	\$
34	Circuit Breaker – 100 3-Pole, Mounted in Exist. 1200A, 277/480V, 3Ø Main Distribution Panel	1	Each	\$	\$
35	Circuit Breaker – 60 3-Pole, Mounted in Exist. 1200A, 277/480V, 3Ø Main Distribution Panel	1	Each	\$	\$
36	Traffic Rated Concrete Man Hole with Steel Lid sized as required.	6	Each	\$	\$
37	Cables - Feeder Cables for Power to High Mast Lighting - #3 AWG Copper with Insulation as Specified in the Contract Documents	150	Linear Foot	\$	\$
38	Cables - Feeder Cables for Power to High Mast Lighting - #4 AWG Copper with Insulation as Specified in the Contract Documents	5,100	Linear Foot	\$	\$
39	Cables - Feeder Cables for Power to High Mast Lighting - #6 AWG Copper with Insulation as Specified in the Contract Documents	5,200	Linear Foot	\$	\$
40	Cables - Grounding - #1/0 AWG Bare Copper as Specified in the Contract Documents	2,000	Linear Foot	\$	\$
41	Cables - Grounding - #8 AWG Copper with Insulation as Specified in the Contract Documents	3,400	Linear Foot	\$	\$
42	1 1/2" RGS Conduit	50	Linear Foot	\$	\$
43	36"x36"x24" Galvanized NEMA 4X Junction Box	1	Each	\$	\$
44	WireWay – NEMA 12 Galvanized Wireway (6"x6"x6')	1	Each	\$	\$

# ASPA Pier C North Rehabilitation

## Phase I – Storage Yard

### ADDENDUM # 4

Item	Description	Approx. Quantities	Unit	Unit Price	Dollar Amount
45	4" RGS Conduit	150	Linear Foot	\$	\$
46	4" Schedule 80 PVC Conduit	4,650	Linear Foot	\$	\$
47	Concrete - Duct Bank Encasement with Red Dye	193	Cubic Yard	\$	\$
48	Trenching	1,180	Linear Foot	\$	\$
49	Remaining miscellaneous items as required for a complete and operational electrical system.	1	Lump Sum	\$	\$
<b>TOTAL BID</b>					\$

\_\_\_\_\_ Dollars  
(In Words)

