



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name Warehouse Roll-Up Door Replacements – Hurricane Sally

Project: 10842 Task: 01

ADDENDUM #2

To: Prospective Bidders

Date: 10/22/2020

The following items are clarifications to questions received and becomes a part of the Bid Package.

Item	Description
1	The bid opening date has been postponed. Delete all previous references to the bid opening and replace with the following: Sealed bid proposals will be received via courier to the Alabama State Port Authority, 1400 Alabama State Docks Blvd, Suite 216, Administration Building, Mobile, AL 36602 by 1:30 P.M. on Thursday, November 5, 2020. Sealed bid proposals can also be hand delivered to the Killian Room starting at 15 minutes prior to the official bid opening at 2:00 PM on Thursday, November 5, 2020 at the Alabama State Port Authority in the International Trade Center building, 250 North Water Street, 1 st floor—Killian Room, Mobile, AL. No bids will be accepted after 2:00 P.M. Faxed, electronic or conditional bids will not be accepted.
2	Delete all previous references to the contract duration and replace with the following: The Contractor will be required to complete the work under the Contract within 180 calendar days after receipt of a "Notice to Proceed". The Contractor must furnish proof of purchase of materials within 10 calendar days after receipt of notice to proceed.
3	The Contractor may elect to furnish dumpsters onsite and is responsible to dispose of all waste material off of ASPA property.
4	The Contractor will be furnished a covered area on the main docks facility for door storage.
5	The Contractor will be permitted to work on weekends if deemed necessary.
6	Where electric motor operators are required to be furnished as part of the door installation, the motor horsepower requirements shall be in accordance with the door manufacturer's recommendations considering the size of the door.
7	The Contractor is responsible to furnish a complete working door system at each location.
8	The Contractor shall submit a fire protection plan to ASPA for review before commencing work. Many of the work areas are directly adjacent to paper products, which are highly flammable. ASPA will make every effort to have these products relocated away from the direct work areas per the Contractors advanced request. ASPA police dispatch must be contacted on a daily basis before hot work is to commence.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

Project Manager:

Marcus Coleman, P.E.
 Facilities Engineer

10/22/2020

Date