



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name Pinto Terminal – DMMA Weir Box Extension 2020

Project 10859 - Task 01

ADDENDUM #1

To: Prospective Bidders

Date: 12/14/2020

This Addendum contains the following documents and becomes a part of the Bid Package.

Item	Description
1	Pre Bid Meeting minutes and answers to submitted questions.
2	Pre-Bid Meeting Attendance Sheet

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

Project Manager:

Marcus Coleman, P.E.
Facilities Engineer

12/14/2020

Date



Alabama State Port Authority
Pre-Bid Meeting Minutes

Project Name Pinto Terminal – DMMA Weir Box
 Extension 2020

Project# 10859 **Task#** 01

Date	12/10/2020	Time	2:00 pm
Location	Pinto Terminal DMMA parking lot	Attendees are indicated on Pre-Bid Meeting Sign-in Sheet	

General Discussion

A Pre-Bid briefing was held with prospective bidders to discuss the project description. A site visit of the Pinto Terminal DMMA existing weir box was performed. Following are the principal points of discussion:

1. The existing weir box height is to be extended by 4 feet. This includes all steel components, except for the wing walls. The wing walls shall remain as-is.
2. The existing handrails, grating, safety gates and walk thru ladders shall be removed from the existing structure and reused on the new extension.
3. A new levee ladder must be installed on the back side of the weir box extension to provide access. The ladder shall be constructed of steel and shall be welded to the weir box extension.
4. The haul road may be used for temporary equipment placement to facilitate the erection of the weir box extension. The Contractor will not be permitted to disrupt traffic on the road, except by prior approval from the project manager.

Attendees Questions:


Question 1: Does the new levee ladder require a safety gate?

Answer: Yes.

Question 2:

Answer:

These minutes are based upon the observation of the writer. Please direct all additions or corrections to these minutes to the Project Manager within seven (7) business days of their receipt.

Prepared by: 	12/14/2020
Marcus Coleman, P.E. Project Manager	Date

